

ENVIRONMENTAL MANAGEMENT DEPARTMENT<http://www.edcgov.us/government/EMD>**PLACERVILLE OFFICE:**

2850 Fairlane Court
Placerville, CA 95667
(530) 621-5300
(530) 642-1531 Fax

LAKE TAHOE OFFICE:

924 B Emerald Bay Rd.
South Lake Tahoe, CA 96150
(530) 573-3450
(530) 542-3364 Fax

December 23, 2020

Gina Pike, Development Services Technician II
El Dorado Irrigation District
2890 Mosquito Road
Placerville, CA 95667

RE: EID Water Connection for APN 092-060-55-100

Ms. Pike,

I have conducted additional reviews to determine the feasibility of drilling a new well on APN 092-060-55-100. As part of the review I spoke with Triangle Well Drilling and conducted additional parcel research.

The parcel has surrounding power lines that prohibit a well drilling rig from accessing the site. There is also a septic system close to the western property line of the parcel that prohibits a new well being drilled that will meet current setback requirements of the El Dorado County Well Ordinance. For these reasons, a new well cannot be drilled on the property that meets requirements or can safely be accessed by a well drilling rig. Please let me know if you have any questions.

Sincerely,

A handwritten signature in black ink that reads "Bryan Vyverberg".

Bryan Vyverberg
Supervising Environmental Health Specialist
bryan.vyverberg@edcgov.us
(530) 621-5924